

August 02, 2023

Kevin Roberts
Professional Service Industries, Inc.
11826 Borman Dr
Maryland Heights, MO 63146
TEL: (314) 432-8073
FAX: (314) 432-5119



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: Coverdell Elementary / 0029-5933-5

WorkOrder: 23071454

Dear Kevin Roberts:

TEKLAB, INC received 44 samples on 7/19/2023 15:43:00 for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Aaron Renner
Project Manager
(630)324-6855
arenner@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 23071454

Client Project: Coverdell Elementary / 0029-5933-5

Report Date: 02-Aug-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	9
Chain of Custody	Appended

Client: Professional Service Industries, Inc.

Work Order: 23071454

Client Project: Coverdell Elementary / 0029-5933-5

Report Date: 02-Aug-23

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.
- DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.
- DNI Did not ignite
- DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.
- LCSDD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- NC Data is not acceptable for compliance purposes
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
- PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.
- RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
- RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
- SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
- Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
- TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count (> 200 CFU)



Definitions

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 23071454

Client Project: Coverdell Elementary / 0029-5933-5

Report Date: 02-Aug-23

Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)



Case Narrative

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 23071454

Client Project: Coverdell Elementary / 0029-5933-5

Report Date: 02-Aug-23

Cooler Receipt Temp: NA °C

This report was revised on August 2, 2023. The reason for the revision is to lower the reporting limit for select samples. Please replace report dated July 31, 2023 with this report. AR 8/2/23

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com



Accreditations

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 23071454

Client Project: Coverdell Elementary / 0029-5933-5

Report Date: 02-Aug-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 23071454

Client Project: Coverdell Elementary / 0029-5933-5

Report Date: 02-Aug-23

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
23071454-001A	CE-WC-CAFÉ-1-1	NELAP		5.0	< 5.0	µg/L	5	07/28/2023 13:32	07/18/2023 10:43
23071454-002A	CE-WC-CAFÉ-1-2	NELAP		1.0	1.1	µg/L	1	07/27/2023 01:56	07/18/2023 10:44
23071454-003A	CE-F-KIT-1-3	NELAP		1.0	1.6	µg/L	1	07/27/2023 02:01	07/18/2023 10:45
23071454-004A	CE-F-KIT-1-4	NELAP		1.0	111	µg/L	1	07/27/2023 02:05	07/18/2023 10:46
23071454-005A	CE-SN-KIT-1-5	NELAP		1.0	< 1.0	µg/L	5	07/28/2023 14:09	07/18/2023 10:47
23071454-006A	CE-IM-KIT-1-6	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 02:34	07/18/2023 10:48
23071454-007A	CE-F-171-1-7	NELAP		1.0	< 1.0	µg/L	5	07/28/2023 14:13	07/18/2023 10:57
23071454-008A	CE-F-171-1-8	NELAP		1.0	< 1.0	µg/L	5	07/28/2023 14:17	07/18/2023 10:58
23071454-009A	CE-F-170-1-9	NELAP		1.0	< 1.0	µg/L	5	07/28/2023 15:27	07/18/2023 10:59
23071454-010A	CE-F-168-1-10	NELAP		1.0	< 1.0	µg/L	5	07/28/2023 14:21	07/18/2023 11:00
23071454-011A	CE-F-157-1-11	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 02:38	07/18/2023 11:01
23071454-012A	CE-F-156-1-12	NELAP		5.0	< 5.0	µg/L	10	07/28/2023 13:28	07/18/2023 11:02
23071454-013A	CE-F-155-1-13	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 02:46	07/18/2023 11:03
23071454-014A	CE-F-154-1-14	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 02:50	07/18/2023 11:04
23071454-015A	CE-WC-C1-1-15	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 16:21	07/18/2023 11:05
23071454-016A	CE-WC-C1-1-16	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 02:54	07/18/2023 11:06
23071454-017A	CE-F-151-1-17	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 02:58	07/18/2023 11:08
23071454-018A	CE-F-153-1-18	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 03:40	07/18/2023 11:09
23071454-019A	CE-F-TWR-1-19	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 11:46	07/18/2023 11:10
23071454-020A	CE-IM-TWR-1-20	NELAP		5.0	< 5.0	µg/L	10	07/28/2023 07:47	07/18/2023 11:11
23071454-021A	CE-F-150-1-21	NELAP		5.0	< 5.0	µg/L	10	07/28/2023 07:51	07/18/2023 11:15
23071454-022A	CE-F-148-1-22	NELAP		5.0	< 5.0	µg/L	10	07/28/2023 08:36	07/18/2023 11:16
23071454-023A	CE-F-147-1-23	NELAP		1.0	< 1.0	µg/L	1	07/28/2023 08:56	07/18/2023 11:17
23071454-024A	CE-F-144-1-24	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 12:28	07/18/2023 11:18
23071454-025A	CE-F-141-1-25	NELAP		5.0	< 5.0	µg/L	5	07/28/2023 08:48	07/18/2023 11:19
23071454-026A	CE-DF-143-1-26	NELAP		5.0	< 5.0	µg/L	5	07/28/2023 08:52	07/18/2023 11:20
23071454-027A	CE-DF-142-1-27	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 12:40	07/18/2023 11:21
23071454-028A	CE-F-140-1-28	NELAP		5.0	< 5.0	µg/L	5	07/28/2023 09:34	07/18/2023 11:22
23071454-029A	CE-DF-138-1-29	NELAP		5.0	< 5.0	µg/L	10	07/28/2023 08:40	07/18/2023 11:23
23071454-030A	CE-F-137-1-30	NELAP		5.0	< 5.0	µg/L	10	07/28/2023 08:44	07/18/2023 11:24
23071454-031A	CE-F-134-1-31	NELAP		1.0	< 1.0	µg/L	1	07/28/2023 09:38	07/18/2023 11:25
23071454-032A	CE-DF-131-1-32	NELAP		1.0	< 1.0	µg/L	1	07/28/2023 09:42	07/18/2023 11:26
23071454-033A	CE-DF-130-1-33	NELAP		1.0	< 1.0	µg/L	1	07/28/2023 09:46	07/18/2023 11:27
23071454-034A	CE-F-125-1-34	NELAP		1.0	< 1.0	µg/L	1	07/26/2023 21:04	07/18/2023 11:28
23071454-035A	CE-DF-127-1-35	NELAP		1.0	< 1.0	µg/L	1	07/26/2023 21:32	07/18/2023 11:29
23071454-036A	CE-DF-126-1-36	NELAP		1.0	< 1.0	µg/L	1	07/26/2023 21:08	07/18/2023 11:30
23071454-037A	CE-F-124-1-37	NELAP		1.0	< 1.0	µg/L	1	07/26/2023 21:12	07/18/2023 11:31
23071454-038A	CE-WC-C2-1-38	NELAP		1.0	< 1.0	µg/L	1	07/26/2023 21:16	07/18/2023 11:32
23071454-039A	CE-WC-C2-1-39	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 01:11	07/18/2023 11:33
23071454-040A	CE-F-NUR-1-40	NELAP		1.0	< 1.0	µg/L	5	07/28/2023 14:25	07/18/2023 11:35
23071454-041A	CE-F-106-1-41	NELAP		4.9	< 4.9	µg/L	20	07/28/2023 14:33	07/18/2023 11:36
23071454-042A	CE-F-103-C1-1-42	NELAP		1.0	< 1.0	µg/L	5	07/28/2023 14:29	07/18/2023 11:37
23071454-043A	CE-BF-C1-1-43	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 01:40	07/18/2023 11:07
23071454-044A	CE-BF-C2-1-44	NELAP		1.0	< 1.0	µg/L	1	07/27/2023 01:44	07/18/2023 11:34



Laboratory Results

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 23071454

Client Project: Coverdell Elementary / 0029-5933-5

Report Date: 02-Aug-23

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
<i>Dilution required to meet internal standard recovery criteria.</i>									
<i>Dilution required to meet internal standard recovery criteria.</i>									
<i>Dilution required to meet internal standard recovery criteria.</i>									
<i>Dilution required to meet internal standard recovery criteria.</i>									
<i>Dilution required to meet internal standard recovery criteria.</i>									
<i>Dilution required to meet internal standard recovery criteria.</i>									
<i>Dilution required to meet internal standard recovery criteria.</i>									
<i>Dilution required to meet internal standard recovery criteria.</i>									
<i>Dilution required to meet internal standard recovery criteria.</i>									
<i>Dilution required to meet internal standard recovery criteria.</i>									



Receiving Check List

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 23071454

Client Project: Coverdell Elementary / 0029-5933-5

Report Date: 02-Aug-23

Carrier: Tyler Maddox

Received By: ANC

Completed by:

Allison Colin

Reviewed by:

Ellie Hopkins

On:

20-Jul-23

Allison Colin

On:

20-Jul-23

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

- Shipping container/cooler in good condition? Yes No Not Present Temp °C NA
- Type of thermal preservation? None Ice Blue Ice Dry Ice
- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Samples in proper container/bottle? Yes No
- Sample containers intact? Yes No
- Sufficient sample volume for indicated test? Yes No
- All samples received within holding time? Yes No
- Reported field parameters measured: Field Lab NA
- Container/Temp Blank temperature in compliance? Yes No

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

- Water - at least one vial per sample has zero headspace? Yes No No VOA vials
- Water - TOX containers have zero headspace? Yes No No TOX containers
- Water - pH acceptable upon receipt? Yes No NA
- NPDES/CWA TCN interferences checked/treated in the field? Yes No NA

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

Client: Professional Service Industries, Inc.
Address: 11826 Borman Dr
City / State / Zip: Maryland Heights, MO 63146
Contact: Kevin Roberts
E-Mail: kevin.roberts@intertek.com
Phone: (314) 432-8073
Fax:

Samples on: ICE BLUE ICE NO ICE LTC
 Preserved in: LAB FIELD FOR LAB USE ONLY
 Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply Yes No
 Are these samples known to be hazardous? Yes No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. Yes No

Project Name/Number
Coverdell Elementary / 0029-5933-5

Sample Collector's Name
KCR

Lab Use Only	Results Requested	Billing Instructions	Date/Time Sampled	# and Type of Containers
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)	Sample Identification			OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES
<i>230714SY</i>	CE - WC - CA - 1-1	7-18-23 / 1043		
	CE - WC - CA - 1-2	1044		
	CE - F - KT - 1-3	1045		
	CE - F - KT - 1-4	1046		
	CE - SN - KT - 1-5	1047		
	CE - EM - KT - 1-6	1048		
	CE - F - 171 - 1-7	1057		
	CE - F - 171 - 1-8	1058		
	CE - F - 170 - 1-9	1059		
	CE - F - 168 - 1-10	1100		

Matrix	INDICATE ANALYSIS REQUESTED	Received By	Date/Time
Drinking Water	X	<i>Sam</i>	7-18-23 12:08
Aqueous	X	<i>William Colan</i>	7-19-23 15:43
Groundwater	X		
Special Waste	X		
Sludge	X		
Soil	X		
Lead	X		

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Relinquished By: *KCR* **Date/Time:** 7-18-23 C 2:00
Sam **Date/Time:** 7-19-23 3:43



TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Professional Service Industries, Inc.
 Address: 11826 Borman Dr
 City / State / Zip: Maryland Heights, MO 63146
 Contact: Kevin Roberts
 E-Mail: kevin.roberts@interspek.com
 Phone: (314) 432-8073
 Fax:

Samples on: ICE BLUE ICE NO ICE °C LTG
 Preserved in: LAB FIELD FOR LAB-USE ONLY
 Lab Notes

Project Name/Number: Coverdell Elementary / 0029-5933-5
 Sample Collector's Name: KCR
 Are these samples known to be involved in litigation? If yes, a surcharge will apply Yes No
 Are these samples known to be hazardous? Yes No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. Yes No

Lab Use Only	Sample Identification	Date/Time Sampled	Billing Instructions	# and Type of Containers	INDICATE ANALYSIS REQUESTED												
					Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead							
<input checked="" type="checkbox"/> Standard	011 CE-F-157-1-11	7-17-23 / 1101		1	X												
<input type="checkbox"/> Other	012 CE-F-156-1-12	/ 1102		1	X												
	013 CE-F-155-1-13	/ 1103		1	X												
	014 CE-F-154-1-14	/ 1104		1	X												
	015 CE-WC-C1-1-15	/ 1105		1	X												
	016 CE-WC-C1-1-16	/ 1106		1	X												
	017 CE-F-151-1-17	/ 1108		1	X												
	018 CE-F-153-1-18	/ 1109		1	X												
	019 CE-F-TWR-1-19	/ 1110		1	X												
	020 CE-IM-TWR-1-20	V / 1111		1	X												

Relinquished By: *[Signature]* Date/Time: 7-18-23 @ 2:00
 Received By: *[Signature]* Date/Time: 7/19 15:43

CHAIN OF CUSTODY

pg. 3 of 5 Work order # 23071454

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Professional Service Industries, Inc. Address: 11826 Borman Dr Maryland Heights, MO 63146 City / State / Zip: Contact: Kevin Roberts kevin.roberts@intertek.com E-Mail: Phone: (314) 432-8073 Fax:	Samples on: <input checked="" type="checkbox"/> ICE <input checked="" type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE °C _____ LTCP _____ Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY Lab Notes: Client Comments:
Are these samples known to be involved in litigation? If yes, a surcharge will apply <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Project Name/Number Coverdell Elementary / 0029-5933-5		Sample Collector's Name Kel																										
Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)	Sample Identification	Billing Instructions	Date/Time Sampled	# and Type of Containers	INDICATE ANALYSIS REQUESTED																							
					OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead										
<input checked="" type="checkbox"/> Lab Use Only	0A1 CE-F-150-1-2-1		7-18-23 / 1115	1																								
	0A2 CE-F-148-1-2-2		/ 1116	1																								
	0A3 CE-F-147-1-2-3		/ 1117	1																								
	0A4 CE-F-144-1-2-4		/ 1118	1																								
	0A5 CE-F-141-1-2-5		/ 1119	1																								
	0A6 CE-DF-143-1-2-6		/ 1120	1																								
	0A7 CE-DF-142-1-2-7		/ 1121	1																								
	0A8 CE-F-140-1-2-8		/ 1122	1																								
	0A9 CE-DF-138-1-2-9		/ 1123	1																								
	0B0 CE-F-137-1-3-0		/ 1124	1																								

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7-18-23 2:10 PM	<i>[Signature]</i>	7-19-23 12:08
<i>[Signature]</i>	7-19-23 3:43	<i>[Signature]</i>	7-19 1543

CHAIN OF CUSTODY

pg. 4 of 5 Work order # 23071454

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Professional Service Industries, Inc.
 11826 Borman Dr
 Maryland Heights, MO 63146
City / State / Zip
Contact: Kevin Roberts
 kevin.roberts@intertek.com
Phone: (314) 432-8073
E-Mail:
Fax:

Samples on: ICE BLUE ICE NO ICE °C °F
 Preserved in: LAB FIELD **FOR LAB USE ONLY**
 Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply Yes No
 Are these samples known to be hazardous? Yes No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. Yes No

Project Name/Number
 Coverdell Elementary / 0029-5933-5

Sample Collector's Name
 KCR

Billing Instructions

Results Requested
 Standard 1-2 Day (100% Surcharge)
 Other 3 Day (50% Surcharge)

Lab Use Only	Sample Identification	Date/Time Sampled	# and Type of Containers
031	CE-F-134-1-31	7-18-23 / 1125	OTHER
032	CE-DF-131-1-32	/ 1126	NaHSO4
033	CE-DF-130-1-33	/ 1127	MeOH
034	CE-F-125-1-34	/ 1128	HCL
035	CE-DF-127-1-35	/ 1129	H2SO4
036	CE-DF-126-1-36	/ 1130	NaOH
037	CE-F-124-1-37	/ 1131	HNO3
038	CE-WC-C2-1-38	/ 1132	UNPRES
039	CE-WC-C2-1-39	/ 1133	
040	CE-F-MWF-1-40	↓ 1135	

MATRIX

Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead
X					X
X					X
X					X
X					X
X					X
X					X
X					X
X					X
X					X
X					X

INDICATE ANALYSIS REQUESTED

OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES

Relinquished By: [Signature]
 Date/Time: 7-18-23 5:29M

Received By: [Signature]
 Date/Time: 7-19-23 12:50P

CHAIN OF CUSTODY

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005
 pg. 5 of 5 Work order # 23071484

Client: Professional Service Industries, Inc. 11826 Borman Dr Maryland Heights, MO 63146 Kevin Roberts kevin.roberts@intertek.com	Address: Professional Service Industries, Inc. 11826 Borman Dr Maryland Heights, MO 63146	City / State / Zip Maryland Heights, MO 63146	Contact: Kevin Roberts kevin.roberts@intertek.com	Phone: (314) 432-8073	Fax:
---	---	---	--	---------------------------------	-------------

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply Yes No
 Are these samples known to be hazardous? Yes No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. Yes No

Project Name/Number Coverdell Elementary / 0029-5933-5	Sample Collector's Name KCR
Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)	Billing Instructions Date/Time Sampled
Lab Use Only D41 CE - F-100-1-41 D42 CE - F-103-1-42 D43 CE - BF-C1-1-43 D44 CE - BF-C2-1-44	7-18-23 / 1136 / 1137 / 1107 / 1134

Matrix	INDICATE ANALYSIS REQUESTED											
	Drinking Water	Aqueous	Soil	Sludge	Special Waste	Groundwater	Lead					
	X	X				X	X					
	X	X				X	X					
	X	X				X	X					
	X	X				X	X					

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7-18-23 2:24M	<i>[Signature]</i>	7-19-23 12:08
<i>[Signature]</i>	7-19-23 3:43	<i>[Signature]</i>	7-19-23 15:03